

Compliance Statement

No. 2024-106A

Data communication cords, Category 6A

Company

KRUGEL EXIM spol. s r.o.
Pri majeri 13
831 06 Bratislava
Slovak Republic

Product description

Screened Category 6A RJ45 cords (equipment, patch, and work area) characterised up to 500 MHz

Product identification

Keline 10Giga patch cables STP Cat.6A, LS0H
Part number: KEL-C6A-P-xxx (xxx: denotes length in dm)

Generic cabling and cabling components standard - Category 6A balanced cord requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018
- IEC 61935-2:2022 (Ed. 4.0) (transmission requirements)

Technical report

12334136-01, DANAK-19/24006

EC Cabling product ID


5008

CS valid until

1 March 2025

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year. This compliance statement has been revised, original issue date 30 January 2024.

Hørsholm, 6 February 2024



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

